



EXCEPTIONS REPORT FOR INDIVIDUAL FILTER MONITORING

(Transfer data from this page to: LT1-ESWTR Summary Section A, Subsection 2-SFN 54272)

North Dakota Department of Health

Division of Municipal Facilities

SFN 54275 (5/2005)

Public Water System (PWS) Name	PWS Number ND _____
Month _____	Year _____

In the spaces below, list all the obvious reasons that apply as to why your system exceeded any of the following:

- A) Individual filter turbidity level greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart.
- B) Individual filter turbidity level greater than 0.5 in 2 consecutive measurements taken 15 minutes apart at the end of 4 hours of operation after a filter has been backwashed or otherwise taken off line.
- C) Individual filter turbidity level greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart in each of 3 consecutive months.
- D) Individual filter turbidity level greater than 2.0 NTU in 2 consecutive measurements taken 15 minutes apart in 2 consecutive months.

Reasons can include filter problems, turbidimeter errors, chemical feed equipment failure, other major unit process failures or maintenance activities.

Filter Number (or name): _____	Date of Exceedance: _____
Details:	

Filter Number (or name): _____	Date of Exceedance: _____
Details:	

Filter Number (or name): _____	Date of Exceedance: _____
Details:	

Filter Number (or name): _____	Date of Exceedance: _____
Details:	